

**Call 04 Intersection Improvements (J-Turn) on US 45 at CR 212, known as Federal Aid Project No. HSIP-0002-02(063) / 106233301 in Clarke County.**

Q1. Can portable water filled barriers be used in place of concrete median barriers?

A1. Water filled barriers will not be allowed as a substitution with the exception of the type specified on the MDOT “Approved Product List” for substitution of concrete median barriers.